

L Tubo (m)=	1
-------------	---

D nominal (mm)	D interno (mm)	D interno (m)	A interna Tubo (m ²)	Gramos Ca(ClO) ₂ (ml) de tubería/D interno (m)
75	66	0.066	0.003421194	0.14
90	79.2	0.0792	0.00492652	0.33
110	96.68	0.09668	0.007341134	0.58
160	141	0.141	0.015614501	1.3
200	176.2	0.1762	0.024383817	2.32
250	220.4	0.2204	0.038151627	3.62
315	277.6	0.2776	0.060524165	5.21
355	312.8	0.3128	0.076846372	7.09
400	352.6	0.3526	0.097646009	9.27
450	396.6	0.3966	0.123536502	11.73
500	440.6	0.4406	0.152468057	14.48

V(m3) agua (ml) de tubería/D interno (m)
0.003421194
0.00492652
0.007341134
0.015614501
0.024383817
0.038151627
0.060524165
0.076846372
0.097646009
0.123536502
0.152468057